



4- 4inch conduits must
be equally spaced within
this 12x12 opening. 12"
min. of conduit must
extend above pad.