

GEA is seeking bids on the following items:

- 1: Any site prep that needs to be performed at locations in order to pour concrete foundations
- 2: Concrete foundation for 11.5 ft by 16 ft shelter
- 3: Concrete foundation for 13 ft by 7 ft generator pad
- 4: Work must be completed at seven sites (approximate foundation sites will be marked with white paint)

1. NoliChuckey Substation	6247 Asheville Highway
2. Baileyton Substation	11845 Baileyton Road
3. Locust Springs Substation	965 Justice Road
4. Snapps Ferry Substation	8435 Snappy Ferry Road
5. Tusculum Substation	85 American Road
6. Erwin Hwy Substation	5075 Erwin Highway
7. Crossroads Substation	4430 107 Cutoff

Please contact Nathan Brown at 423 588 8189 to set up a time to visit sites if needed.

Building specs:

Pad must be 11.5 ft by 16 ft and square

Pad needs to be 4 inches above existing grade

A 12 inch by 18 inch footer should be around the outside edge of the pad, remaining pad can be a minimum of 4 inches deep

All concrete must be reinforced with ½ rebar every 24 inches

4 - 4 inch conduits will be installed in slab and run to a vault. 4 conduits will exit vault and turned up at power pole to be set by GEA. 1- 4 inch conduit will be run from building pad to the GEA pole for electric service.

Generator Pad

Pad must be 13 ft by 7 ft

Pad may be a min 2 inches and max 6 inches above existing grade

Pad must be 12 inches deep and reinforced with ½ rebar every 24 inches

1 – 4 inch conduit and 1 – 1 inch conduit will be installed in slab and the ends marked on the outside of pad. (conduit and 90 degree sweeps will be provided by GEA)